

VOC Content Test Certificate

Thursday 17th December 2020

Supplier: Parchem Construction Supplies Pty Ltd (7 Lucca Rd, Wyong, NSW 2259, Australia)

Product Description: Fosroc® Nitoflor® FC150 HP

Date Tested: December 2020 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings Materials. ASTM D3960 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:


Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B	Fosroc® Nitoflor® FC150 HP
One and Two Pack Performance Coatings for Floors: 140 grams per Liter	11 grams per Liter as VOC content per material
<p><i>We hereby certify that Fosroc® Nitoflor® FC150 HP is below the VOC Content limits of chosen categories specified by Green Star Design, Green Building Council of Australia</i></p>	



Dr. Vyt Garnys
 PhD, BSc (Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant



Dr. Tuan Duong
 PhD, BEng (Chem. Eng.)
 Senior Consultant



Travis Hale
 BSc (Biotechnology)
 Senior Consultant

V2012002A